

Oil water drainage systems - External Area

1 : 350

DR - Legenda Tubazioni

DR - Pipe Systems Legend

OD — Scarico Acque Oleose / *Oil water*

PUBLIC HEALTH SERVICES NOTES:
- All drainage ducts is to be equipped of inspectable trap, extended all the way to the roof and well ventilated.
- Each drainage system must be equipped with a trap with a water seal of at least 50 mm and not more than 100 mm. dry anti-odor trap interposition.
- The waste water collections shall be separated from the ones they flow into prom inspectable trap interposition.
- The rainwater collections shall be separated from soil waste water system up to drain pits that are located upstream of the public sewage inspection block.
- The rainwater collection shall be equipped with a device for the separation of oils and fats and with a collection tank equipped with electro-pumps.
- The testing operations shall be completed maintaining the drainage system visible and smooth.
- Providing inspection points for main drain pipe upstream of each connection, elbow or special fitting.
- Inspection points shall be installed in accordance with the following indications; must have the following minimum slopes:
  Drainage branches to vertical stack ——— i=2%
  Horizontal drainage pipe ——— i=1%
  Rainwater/Oil water ——— i=0,20%

TYPICAL SECTION OF MAIN DRAIN PIPE ON DIFFERENT SURFACES

TYPICAL SECTION OF DRAINAGE BRANCHES TO MAIN DRAIN

TYPICAL SECTION OF CONNECTION BETWEEN PRESSURIZED DRAIN PIPE TO DRAINAGE SYSTEM

GENERAL NOTES:
- The present drawing is valid for mechanical systems object of tender only.
- Dimensions and measurements shall be verified and confirmed by the tenderer on site by the contractor, who must promptly give notice of possible interferences.
- Possible non-surveyed systems shall be promptly withdrawn realized, they shall be inscribed and their functioning reactivated by the contractor.
- Accurate positions of equipment, materials, piping, ducts, connections to existing systems shall be defined by the contractor and submitted to the works supervisor.
- Any deviations from the project shall be communicated to the works supervisor.
- All equipment shall be easily reachable and accessible through access panels or similar solutions, including where not explicitly indicated.
- The contractor shall size and certify all supports in a workmanlike manner and in respect of every prescription regarding antiseismic design.
- Installations of electric or other kind shall be carried out in accordance with the regulations in force at the time of the works.
- Installations of electronic or site shall comply with every prescription and recommendation by the producers and by the highest trade standards in the relevant fields, including acoustics and fire prevention.
- Any work not considered and described, evaluated based on available documentation, shall be reevaluated and analyzed during the construction phase, after system verification following relevant works shall be executed.
- The contractor shall promptly inform the project and give notice of any discovery, incompleteness o discrepancy with any code or law.
- In case of piping or duct material change, the same pressure drop of the design material shall be guaranteed.
- Any proposed modification to the project shall be submitted to the supervisor and approved by the project supervisor for approval.
- Every infrastructure needed to deliver functioning and testable systems shall be verified on site by the contractor.
- The bottom tube measurements refer to the project Zero Level.

Manhole - Tag

Object code — AAAA
Height — AAA — mm — number of units
Object code — AAAA

PROTOCOLLO | IL RICHIEDENTE | IL PROGETTISTA

NO. | DATA / DATE | DESCRIZIONE / DESCRIPTION

L22 S.p.a. a unico socio
Lombardini22 S.r.l.
Via Lombardini 22
20143 Milano - Italia
T. +39 02 36 59 31
FAX 02 36 59 32 00
Capitale sociale Euro 100.000 i.v.
C.F. e P.IVA 08911820962 - REA 1927888
Sistema di gestione qualità conforme alla UNI EN ISO 9001:2008 - Certificato N. 50 100 8219 da TÜV Italia

STRUTTURE
SPS
Ing. Arturo Donadio
S.P.S. S.r.l.
Via Cavour, 64 - 25128 Milano, Italia
www.sps-srl.it
info@sps-srl.it
T. 0236584007

COMMITTENTE / CLIENT:
INFRASTRUCTURE ITALIA LAND 4 S.r.l
via del Bosco Rinnovato 8 - Palazzo U4 20090 Assago (MI)

PROGETTO / PROJECT:
MIL U4 - Fase 04 Costruzione edificio MIL 04.B e cabina di alta tensione
Alzaia Naviglio Pavese snc, Vellezzo Bellini (PV)

PROGETTISTA / DESIGNER:
Lombardini 22, via Lombardini 22, Milano - Ing. Roberto Cereda
Iscritto all'Ordine degli Ingegneri di Brescia n. A2609

OGGETTO / OBJECT:
SCIA (ai sensi dell'art.23 del DPR 380/2001) intervento di nuova costruzione a seguito di demolizione di edifici a destinazione produttiva, pti in variante a SCIA art. 23 prot. 27791 del 09-05-2023, SCIA art.22 prot.60082 del 09-09-2023 e SCIA art.22 prot. 82343 del 10-10-2023.

TITOLO / DESCRIPTION:
Impianti meccanici
Scarico acque oleose - Aree esterne

DISEGNATO DA: / DRAWN BY:	CONTROLLATO DA: / CHECKED BY:	DATA / DATE:	SCALA / SCALE:	DATA REV.:
APT	MIC	13/10/2023	1:350	-

FORMATO: / FORMAT:	NOME FILE / FILE NAME:	COMMESSA / JOB:	TAVOLA / DRAWING:	REV.:
A0+ = = =	3604_AMB0007-G	3604	AMB0007-G	-

© Lombardini22 S.r.l. - Tutti i diritti riservati - All rights reserved